


 Cite this: *RSC Adv.*, 2025, 15, 2523

Correction: Investigation of a flexible, room-temperature fiber-shaped NH₃ sensor based on PANI–Au–SnO₂

 Qiuning Wang,^{†a} Yuan Peng,^{†a} Bin Guo,^b Jianhai Sun,^{*c} Yaxia Liu,^{*d} Yanjun Wang^e and Hongyan Zhang^{*a}

DOI: 10.1039/d5ra90009c

rsc.li/rsc-advances

 Correction for 'Investigation of a flexible, room-temperature fiber-shaped NH₃ sensor based on PANI–Au–SnO₂' by Qiuning Wang *et al.*, *RSC Adv.*, 2024, 14, 38530–38538, <https://doi.org/10.1039/D4RA06915C>.

The authors regret that there was an error in the sentence on lines 10–11 of the left column on page 38535, in the second paragraph of section 3.4. The text originally read: 'The responses to CO, H₂S, NO₂, NH₃, SO₂, and H₂ equaled 1.04, 1.05, 1.00, 1.12, 0.10, and 0.20, respectively.' This sentence should read: 'The responses to H₂, NH₃, CO, and SO₂ equaled 0.20, 1.12, 0, and 0.10, respectively.'

A higher resolution version of Fig. 7 has also been included.

^aBeijing Key Laboratory of Clothing Materials R&D and Assessment, Beijing Engineering Research Center of Textile Nanofiber, Beijing Institute of Fashion Technology, Beijing, 100029, P. R. China. E-mail: zhyzzh@126.com

^bZhongshan Institute of Changchun University of Science and Technology, P. R. China

^cState Key Laboratory of Transducer Technology, Aerospace Information Research Institute, Chinese Academy of Sciences, Beijing, 100194, P. R. China

^dSchool of Fashion, Beijing Institute of Fashion, China

^eBeijing Institute of Fashion Technology, School of Fashion Flat Knitting Machine Lab, China

[†] Both authors contribute equally to this work.






Fig. 7 (a) Response of fiber-shaped sensor towards different interference gases with a concentration of 40 ppm. (b) Cycling response toward 40 ppm NH₃ at room temperature. (c) Response value of the NH₃ sensor at different operating temperatures. (d) Response changes of NH₃ sensors after different bending cycles. (e) Response values of the NH₃ sensor at different relative humidities. (f) Temporal stability of the NH₃ sensors.

The Royal Society of Chemistry apologises for these errors and any consequent inconvenience to authors and readers.

